

IpConv Protocol Stack

IEC104Slave

**IEC 60870-5-104 Controlled Station
Interoperability**

IPCOMM GmbH
Gundstrasse 15
D-91056 Erlangen
Germany

Voice: +49 9131 92076 0
Fax: +49 9131 92076 10
Email: info@ipcomm.de

© IPCOMM GmbH 1994-2011
All rights reserved

9 Interoperability

This companion standard presents sets of parameters and alternatives from which subsets must be selected to implement particular telecontrol systems. Certain parameter values, such as the choice of "structured" or "unstructured" fields of the INFORMATION OBJECT ADDRESS of ASDUs represent mutually exclusive alternatives. This means that only one value of the defined parameters is admitted per system. Other parameters, such as the listed set of different process information in command and in monitor direction allow the specification of the complete set or subsets, as appropriate for given applications. This clause summarizes the parameters of the previous clauses to facilitate a suitable selection for a specific application. If a system is composed of equipment stemming from different manufacturers, it is necessary that all partners agree on the selected parameters.

The interoperability list is defined as in IEC 60870-5-101 and extended with parameters used in this standard. The text descriptions of parameters which are not applicable to this companion standard are strike-through (corresponding check box is marked black).

NOTE In addition, the full specification of a system may require individual selection of certain parameters for certain parts of the system, such as the individual selection of scaling factors for individually addressable measured values.

The selected parameters should be marked in the white boxes as follows:

- Function or ASDU is not used
- Function or ASDU is used as standardized (default)
- Function or ASDU is used in reverse mode
- Function or ASDU is used in standard and reverse mode

The possible selection (blank, X, R, or B) is specified for each specific clause or parameter.

A black check box indicates that the option cannot be selected in this companion standard.

9.1 System or device

(system-specific parameter, indicate definition of a system or a device by marking one of the following with "X")

- System definition
- Controlling station definition (Master)
- Controlled station definition (Slave)

9.2 Network configuration

(network-specific parameter, all configurations that are used are to be marked "X")

- | | |
|--|--|
| <input checked="" type="checkbox"/> Point-to-point | <input checked="" type="checkbox"/> Multipoint- |
| <input checked="" type="checkbox"/> Multiple point-to-point | <input checked="" type="checkbox"/> Multipoint-star |

9.3 Physical layer

(network-specific parameter, all interfaces and data rates that are used are to be marked "X")

Transmission speed (control direction)

| Unbalanced interchange Circuit V.24/V.28 Standard | Unbalanced interchange Circuit V.24/V.28 Recommended if >1 200 bit/s | Balanced interchange Circuit X.24/X.27 | |
|---|--|---|---------------------------------------|
| <input type="checkbox"/> 100 bit/s | <input type="checkbox"/> 2 400 bit/s | <input type="checkbox"/> 2 400 bit/s | <input type="checkbox"/> 56 000 bit/s |
| <input type="checkbox"/> 200 bit/s | <input type="checkbox"/> 4 800 bit/s | <input type="checkbox"/> 4 800 bit/s | <input type="checkbox"/> 64 000 bit/s |
| <input type="checkbox"/> 300 bit/s | <input type="checkbox"/> 9 600 bit/s | <input type="checkbox"/> 9 600 bit/s | |
| <input type="checkbox"/> 600 bit/s | | <input type="checkbox"/> 19 200 bit/s | |
| <input type="checkbox"/> 1 200 bit/s | | <input type="checkbox"/> 38 400 bit/s | |

Transmission speed (monitor direction)

| Unbalanced interchange Circuit V.24/V.28 Standard | Unbalanced interchange Circuit V.24/V.28 Recommended if >1 200 bit/s | Balanced interchange Circuit X.24/X.27 | |
|---|--|---|---------------------------------------|
| <input type="checkbox"/> 100 bit/s | <input type="checkbox"/> 2 400 bit/s | <input type="checkbox"/> 2 400 bit/s | <input type="checkbox"/> 56 000 bit/s |
| <input type="checkbox"/> 200 bit/s | <input type="checkbox"/> 4 800 bit/s | <input type="checkbox"/> 4 800 bit/s | <input type="checkbox"/> 64 000 bit/s |
| <input type="checkbox"/> 300 bit/s | <input type="checkbox"/> 9 600 bit/s | <input type="checkbox"/> 9 600 bit/s | |
| <input type="checkbox"/> 600 bit/s | | <input type="checkbox"/> 19 200 bit/s | |
| <input type="checkbox"/> 1 200 bit/s | | <input type="checkbox"/> 38 400 bit/s | |

9.4 Link layer

(network-specific parameter, all options that are used are to be marked "X". Specify the maximum frame length. If a non-standard assignment of class 2 messages is implemented for unbalanced transmission, indicate the Type ID and COT of all messages assigned to class 2.)

~~Frame format FT 1.2, single character 1 and the fixed time out interval are used exclusively in this companion standard.~~

Link transmission

- Balanced transmission
- Unbalanced transmission

Frame length

- Maximum length L
(number of octets)

Address field of the link

- not present (balanced transmission only)
- One octet
- Two octets
- Structured
- Unstructured

When using an unbalanced link layer, the following ASDU types are returned in class 2 messages (low priority) with the indicated causes of transmission:

The standard assignment of ASDUs to class 2 messages is used as follows:

| Type identification | Cause of transmission |
|---------------------|-----------------------|
| 9, 11, 13, 21 | <1> |

A special assignment of ASDUs to class 2 messages is used as follows:

| Type identification | Cause of transmission |
|---------------------|-----------------------|
| | |
| | |
| | |
| | |

Note: (In response to a class 2 poll, a controlled station may respond with class 1 data when there is no class 2 data available).

9.5 Application layer

Transmission mode for application data

Mode 1 (Least significant octet first), as defined in 4.10 of IEC 60870-5-4, is used exclusively in this companion standard.

Common address of ASDU

(system-specific parameter, all configurations that are used are to be marked "X")

One octet Two octets

Information object address

(system-specific parameter, all configurations that are used are to be marked "X")

One octet Structured
 Two octets Unstructured
 Three octets

Cause of transmission

(system-specific parameter, all configurations that are used are to be marked "X")

One octet Two octets (with originator address).
 Originator address
 is set to zero if not used

Length of APDU

(system-specific parameter, specify the maximum length of the APDU per system)

The maximum length of the APDU is 253 (default). The maximum length may be reduced by the system.

Maximum length of APDU per system

Selection of standard ASDUs

Process information in monitor direction

(station-specific parameter, mark each Type ID "X" if it is only used in the standard direction, "R" if only used in the reverse direction, and "B" if used in both directions).

| | | |
|--------------------------|--|----------------------|
| B | <1> := Single-point information | M_SP_NA_1 |
| ■ | <2> := Single-point information with time tag | M_SP_TA_1 |
| B | <3> := Double-point information | M_DP_NA_1 |
| ■ | <4> := Double-point information with time tag | M_DP_TA_1 |
| B | <5> := Step position information | M_ST_NA_1 |
| ■ | <6> := Step position information with time tag | M_ST_TA_1 |
| B | <7> := Bitstring of 32 bit | M_BO_NA_1 |
| ■ | <8> := Bitstring of 32 bit with time tag | M_BO_TA_1 |
| B | <9> := Measured value, normalized value | M_ME_NA_1 |
| ■ | <10> := Measured value, normalized value with time tag | M_ME_TA_1 |
| B | <11> := Measured value, scaled value | M_ME_NB_1 |
| ■ | <12> := Measured value, scaled value with time tag | M_ME_TB_1 |
| B | <13> := Measured value, short floating point value | M_ME_NC_1 |
| ■ | <14> := Measured value, short floating point value with time tag | M_ME_TC_1 |
| B | <15> := Integrated totals | M_IT_NA_1 |
| ■ | <16> := Integrated totals with time tag | M_IT_TA_1 |
| ■ | <17> := Event of protection equipment with time tag | M_EP_TA_1 |
| ■ | <18> := Packed start events of protection equipment with time tag | M_EP_TB_1 |
| ■ | <19> := Packed output circuit information of protection equipment with time tag | M_EP_TC_1 |
| <input type="checkbox"/> | <20> := Packed single-point information with status change detection | M_SP_NA_1 |
| X | <21> := Measured value, normalized value without quality descriptor | M_ME_ND_1 |
| B | <30> := Single-point information with time tag CP56Time2a | M_SP_TB_1 |
| B | <31> := Double-point information with time tag CP56Time2a | M_DP_TB_1 |
| B | <32> := Step position information with time tag CP56Time2a | M_ST_TB_1 |
| B | <33> := Bitstring of 32 bit with time tag CP56Time2a | M_BO_TB_1 |
| B | <34> := Measured value, normalized value with time tag CP56Time2a | M_ME_TD_1 |
| B | <35> := Measured value, scaled value with time tag CP56Time2a | M_ME_TE_1 |
| B | <36> := Measured value, short floating point value with time tag CP56Time2a | M_ME_TF_1 |
| B | <37> := Integrated totals with time tag CP56Time2a | M_IT_TB_1 |
| X | <38> := Event of protection equipment with time tag CP56Time2a | M_EP_TD_1 |
| X | <39> := Packed start events of protection equipment with time tag CP56Time2a | M_EP_TE_1 |
| X | <40> := Packed output circuit information of protection equipment with time tag CP56Time2a | M_EP_TF_1 |

Either the ASDUs of the set <2>, <4>, <6>, <8>, <10>, <12>, <14>, <16>, <17>, <18>, <19> or of the set <30> – <40> are used.

Process information in control direction

(station-specific parameter, mark each Type ID "X" if it is only used in the standard direction, "R" if only used in the reverse direction, and "B" if used in both directions).

| | | |
|----------|--|-----------|
| B | <45> := Single command | C_SC_NA_1 |
| B | <46> := Double command | C_DC_NA_1 |
| B | <47> := Regulating step command | C_RC_NA_1 |
| B | <48> := Set point command, normalized value | C_SE_NA_1 |
| B | <49> := Set point command, scaled value | C_SE_NB_1 |
| B | <50> := Set point command, short floating point value | C_SE_NC_1 |
| B | <51> := Bitstring of 32 bit | C_BO_NA_1 |
| B | <58> := Single command with time tag CP56Time2a | C_SC_TA_1 |
| B | <59> := Double command with time tag CP56Time2a | C_DC_TA_1 |
| B | <60> := Regulating step command with time tag CP56Time2a | C_RC_TA_1 |
| B | <61> := Set point command, normalized value with time tag CP56Time2a | C_SE_TA_1 |
| B | <62> := Set point command, scaled value with time tag CP56Time2a | C_SE_TB_1 |
| B | <63> := Set point command, short floating point value with time tag CP56Time2a | C_SE_TC_1 |
| B | <64> := Bitstring of 32 bit with time tag CP56Time2a | C_BO_TA_1 |

Either the ASDUs of the set <45> – <51> or of the set <58> – <64> are used.

System information in monitor direction

(station-specific parameter, mark "X" if used)

| | | |
|----------|-------------------------------|-----------|
| B | <70> := End of initialization | M_EI_NA_1 |
|----------|-------------------------------|-----------|

System information in control direction

(station-specific parameter, mark each Type ID "X" if it is only used in the standard direction, "R" if only used in the reverse direction, and "B" if used in both directions).

| | | |
|----------|--|----------------------|
| B | <100>:= Interrogation command | C_IC_NA_1 |
| B | <101>:= Counter interrogation command | C_CI_NA_1 |
| X | <102>:= Read command | C_RD_NA_1 |
| X | <103>:= Clock synchronization command (option see 7.6) | C_CS_NA_1 |
| ■ | <104>:= Test command | C_TS_NA_1 |
| X | <105>:= Reset process command | C_RP_NA_1 |
| ■ | <106>:= Delay acquisition command | C_CD_NA_1 |
| B | <107>:= Test command with time tag CP56Time2a | C_TS_TA_1 |

Parameter in control direction

(station-specific parameter, mark each Type ID "X" if it is only used in the standard direction, "R" if only used in the reverse direction, and "B" if used in both directions).

| | | |
|-------------------------------------|---|-----------|
| <input checked="" type="checkbox"/> | <110>:= Parameter of measured value, normalized value | P_ME_NA_1 |
| <input checked="" type="checkbox"/> | <111>:= Parameter of measured value, scaled value | P_ME_NB_1 |
| <input checked="" type="checkbox"/> | <112>:= Parameter of measured value, short floating point value | P_ME_NC_1 |
| <input type="checkbox"/> | <113>:= Parameter activation | P_AC_NA_1 |

File transfer

(station-specific parameter, mark each Type ID "X" if it is only used in the standard direction, "R" if only used in the reverse direction, and "B" if used in both directions).

| | | |
|--------------------------|--|-----------|
| <input type="checkbox"/> | <120>:= File ready | F_FR_NA_1 |
| <input type="checkbox"/> | <121>:= Section ready | F_SR_NA_1 |
| <input type="checkbox"/> | <122>:= Call directory, select file, call file, call section | F_SC_NA_1 |
| <input type="checkbox"/> | <123>:= Last section, last segment | F_LS_NA_1 |
| <input type="checkbox"/> | <124>:= Ack file, ack section | F_AF_NA_1 |
| <input type="checkbox"/> | <125>:= Segment | F_SG_NA_1 |
| <input type="checkbox"/> | <126>:= Directory {blank or X, only available in monitor (standard) direction} | F_DR_TA_1 |

Type identifier and cause of transmission assignments (station-specific parameters)

Shaded boxes: option not required.

Black boxes: option not permitted in this companion standard

Blank: functions or ASDU not used.

Mark Type Identification/Cause of transmission combinations:

"X" if only used in the standard direction;

"R" if only used in the reverse direction;

"B" if used in both directions.

| Type identification | | Cause of transmission | | | | | | | | | | | | | | | | | | | |
|---------------------|-----------|-----------------------|---|---|---|---|---|---|---|---|----|----|----|----|----------------|----------------|----|----|----|----|--|
| | | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 20 to 36 | 37 to 41 | 44 | 45 | 46 | 47 | |
| <1> | M_SP_NA_1 | | X | B | | | | | | | | B | B | | B | | | | | | |
| <2> | M_SP_TA_1 | | | | | | | | | | | | | | | | | | | | |
| <3> | M_DP_NA_1 | | X | B | | | | | | | | B | B | | B | | | | | | |
| <4> | M_DP_TA_1 | | | | | | | | | | | | | | | | | | | | |
| <5> | M_ST_NA_1 | | X | B | | | | | | | | B | B | | B | | | | | | |
| <6> | M_ST_TA_1 | | | | | | | | | | | | | | | | | | | | |
| <7> | M_BO_NA_1 | | X | B | | | | | | | | | | | B | | | | | | |
| <8> | M_BO_TA_1 | | | | | | | | | | | | | | | | | | | | |
| <9> | M_ME_NA_1 | X | X | B | | | | | | | | | | | B | | | | | | |
| <10> | M_ME_TA_1 | | | | | | | | | | | | | | | | | | | | |
| <11> | M_ME_NB_1 | X | X | B | | | | | | | | | | | B | | | | | | |
| <12> | M_ME_TB_1 | | | | | | | | | | | | | | | | | | | | |
| <13> | M_ME_NC_1 | X | X | B | | | | | | | | | | | B | | | | | | |
| <14> | M_ME_TC_1 | | | | | | | | | | | | | | | | | | | | |
| <15> | M_IT_NA_1 | | | B | | | | | | | | | | | | B | | | | | |
| <16> | M_IT_TA_1 | | | | | | | | | | | | | | | | | | | | |
| <17> | M_EP_TA_1 | | | | | | | | | | | | | | | | | | | | |
| <18> | M_EP_TB_1 | | | | | | | | | | | | | | | | | | | | |
| <19> | M_EP_TC_1 | | | | | | | | | | | | | | | | | | | | |
| <20> | M_PS_NA_1 | | | | | | | | | | | | | | | | | | | | |
| <21> | M_ME_ND_1 | X | X | X | | | | | | | | | | | X | | | | | | |
| <30> | M_SP_TB_1 | | | B | | X | | | | | | B | B | | | | | | | | |
| <31> | M_DP_TB_1 | | | B | | X | | | | | | B | B | | | | | | | | |
| <32> | M_ST_TB_1 | | | B | | X | | | | | | B | B | | | | | | | | |
| <33> | M_BO_TB_1 | | | B | | X | | | | | | | | | | | | | | | |
| <34> | M_ME_TD_1 | | | B | | X | | | | | | | | | | | | | | | |
| <35> | M_ME_TE_1 | | | B | | X | | | | | | | | | | | | | | | |
| <36> | M_ME_TF_1 | | | B | | X | | | | | | | | | | | | | | | |
| <37> | M_IT_TB_1 | | | B | | | | | | | | | | | | B | | | | | |
| <38> | M_EP_TD_1 | | | X | | | | | | | | | | | | | | | | | |
| <39> | M_EP_TE_1 | | | X | | | | | | | | | | | | | | | | | |
| <40> | M_EP_TF_1 | | | X | | | | | | | | | | | | | | | | | |
| <45> | C_SC_NA_1 | | | | | B | B | B | B | B | | | | | | | X | X | X | X | |
| <46> | C_DC_NA_1 | | | | | B | B | B | B | B | | | | | | | X | X | X | X | |
| <47> | C_RC_NA_1 | | | | | B | B | B | B | B | | | | | | | X | X | X | X | |
| <48> | C_SE_NA_1 | | | | | B | B | B | B | B | | | | | | | X | X | X | X | |
| <49> | C_SE_NB_1 | | | | | B | B | B | B | B | | | | | | | X | X | X | X | |

| Type identification | | Cause of transmission | | | | | | | | | | | | | | | | | | |
|---------------------|------------|-----------------------|---|---|---|---|---|---|---|---|----|----|----|----|----------------|----------------|----|----|----|----|
| | | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 | 12 | 13 | 20 to 36 | 37 to 41 | 44 | 45 | 46 | 47 |
| <50> | C_SE_NC_1 | | | | | | B | B | B | B | B | | | | | | X | X | X | X |
| <51> | C_BO_NA_1 | | | | | | B | B | B | B | B | | | | | | X | X | X | X |
| <58> | C_SC_TA_1 | | | | | | B | B | B | B | B | | | | | | X | X | X | X |
| <59> | C_DC_TA_1 | | | | | | B | B | B | B | B | | | | | | X | X | X | X |
| <60> | C_RC_TA_1 | | | | | | B | B | B | B | B | | | | | | X | X | X | X |
| <61> | C_SE_TA_1 | | | | | | B | B | B | B | B | | | | | | X | X | X | X |
| <62> | C_SE_TB_1 | | | | | | B | B | B | B | B | | | | | | X | X | X | X |
| <63> | C_SE_TC_1 | | | | | | B | B | B | B | B | | | | | | X | X | X | X |
| <64> | C_BO_TA_1 | | | | | | B | B | B | B | B | | | | | | X | X | X | X |
| <70> | M_EI_NA_1* | | | | X | | | | | | | | | | | | | | | |
| <100> | C_IC_NA_1 | | | | | | B | B | X | X | B | | | | | | B | B | B | B |
| <101> | C_CI_NA_1 | | | | | | B | B | | | B | | | | | | B | B | B | B |
| <102> | C_RD_NA_1 | | | | | X | | | | | | | | | | | X | X | X | X |
| <103> | C_CS_NA_1 | | | X | | | X | X | | | | | | | | | X | X | X | |
| <104> | C_TS_NA_1 | | | | | | | | | | | | | | | | | | | |
| <105> | C_RP_NA_1 | | | | | | X | X | | | | | | | | | X | X | X | |
| <106> | C_CD_NA_1 | | | | | | | | | | | | | | | | | | | |
| <107> | C_TS_TA_1 | | | | | | B | B | | | | | | | | | B | B | B | |
| <110> | P_ME_NA_1 | | | | | | X | X | | | | | | | | | X | | X | X |
| <111> | P_ME_NB_1 | | | | | | X | X | | | | | | | | | X | | X | X |
| <112> | P_ME_NC_1 | | | | | | X | X | | | | | | | | | X | | X | X |
| <113> | P_AC_NA_1 | | | | | | | | | | | | | | | | | | | |
| <120> | F_FR_NA_1 | | | | | | | | | | | | | | | | | | | |
| <121> | F_SR_NA_1 | | | | | | | | | | | | | | | | | | | |
| <122> | F_SC_NA_1 | | | | | | | | | | | | | | | | | | | |
| <123> | F_LS_NA_1 | | | | | | | | | | | | | | | | | | | |
| <124> | F_AF_NA_1 | | | | | | | | | | | | | | | | | | | |
| <125> | F_SG_NA_1 | | | | | | | | | | | | | | | | | | | |
| <126> | F_DR_TA_1* | | | | | | | | | | | | | | | | | | | |

* Blank or X only

9.6 Basic application functions

Station initialization

(station-specific parameter, mark "X" if function is used)

Remote initialization

Cyclic data transmission

(station-specific parameter, mark "X" if function is only used in the standard direction, "R" if only used in the reverse direction, and "B" if used in both directions)

Cyclic data transmission

Read procedure

(station-specific parameter, mark "X" if function is only used in the standard direction, "R" if only used in the reverse direction, and "B" if used in both directions)

Read procedure

Spontaneous transmission

(station-specific parameter, mark "X" if function is only used in the standard direction, "R" if only used in the reverse direction, and "B" if used in both directions)

Spontaneous transmission

Double transmission of information objects with cause of transmission spontaneous

(station-specific parameter, mark each information type "X" where both a Type ID without time and corresponding Type ID with time are issued in response to a single spontaneous change of a monitored object)

The following type identifications may be transmitted in succession caused by a single status change of an information object. The particular information object addresses for which double transmission is enabled are defined in a project-specific list.

Single-point information M_SP_NA_1, M_SP_TA_1, M_SP_TB_1 and M_PS_NA_1 *

Double-point information M_DP_NA_1, M_DP_TA_1 and M_DP_TB_1 *

Step position information M_ST_NA_1, M_ST_TA_1 and M_ST_TB_1 *

Bitstring of 32 bit M_BO_NA_1, M_BO_TA_1 and M_BO_TB_1 *

Measured value, normalized value M_ME_NA_1, M_ME_TA_1, M_ME_ND_1 and M_ME_TD_1 *

Measured value, scaled value M_ME_NB_1, M_ME_TB_1 and M_ME_TE_1 *

Measured value, short floating point number M_ME_NC_1, M_ME_TC_1 and M_ME_TF_1 *

* This behavior is subject to configuration

Station interrogation

(station-specific parameter, mark "X" if function is only used in the standard direction, "R" if only used in the reverse direction, and "B" if used in both directions).

| | | |
|---|--|--|
| <input checked="" type="checkbox"/> global | | |
| <input checked="" type="checkbox"/> group 1 | <input checked="" type="checkbox"/> group 7 | <input checked="" type="checkbox"/> group 13 |
| <input checked="" type="checkbox"/> group 2 | <input checked="" type="checkbox"/> group 8 | <input checked="" type="checkbox"/> group 14 |
| <input checked="" type="checkbox"/> group 3 | <input checked="" type="checkbox"/> group 9 | <input checked="" type="checkbox"/> group 15 |
| <input checked="" type="checkbox"/> group 4 | <input checked="" type="checkbox"/> group 10 | <input checked="" type="checkbox"/> group 16 |
| <input checked="" type="checkbox"/> group 5 | <input checked="" type="checkbox"/> group 11 | |
| <input checked="" type="checkbox"/> group 6 | <input checked="" type="checkbox"/> group 12 | |

Information object addresses assigned to each group must be shown in a separate table.

Clock synchronization

(station-specific parameter, mark "X" if function is only used in the standard direction, "R" if only used in the reverse direction, and "B" if used in both directions).

- Clock synchronization
- Day of week used
- RES1, GEN (time tag substituted/ not substituted) used
- SU-bit (summertime) used

optional, see 7.6

Command transmission

(object-specific parameter, mark "X" if function is only used in the standard direction, "R" if only used in the reverse direction, and "B" if used in both directions).

- Direct command transmission
- Direct set point command transmission
- Select and execute command
- Select and execute set point command
- C_SE ACTTERM used
- No additional definition
- Short-pulse duration (duration determined by a system parameter in the outstation)
- Long-pulse duration (duration determined by a system parameter in the outstation)
- Persistent output
- Supervision of maximum delay in command direction of commands and set point commands
- adjustable** Maximum allowable delay of commands and set point commands

Transmission of integrated totals

(station- or object-specific parameter, mark "X" if function is only used in the standard direction, "R" if only used in the reverse direction, and "B" if used in both directions).

- Mode A: Local freeze with spontaneous transmission
- Mode B: Local freeze with counter interrogation
- Mode C: Freeze and transmit by counter-interrogation commands
- Mode D: Freeze by counter-interrogation command, frozen values reported

- Counter read
- Counter freeze without reset
- Counter freeze with reset
- Counter reset

- General request counter
- Request counter group 1
- Request counter group 2
- Request counter group 3
- Request counter group 4

Parameter loading

(object-specific parameter, mark "X" if function is only used in the standard direction, "R" if only used in the reverse direction, and "B" if used in both directions).

- Threshold value
- Smoothing factor
- Low limit for transmission of measured values
- High limit for transmission of measured values

Parameter activation

(object-specific parameter, mark "X" if function is only used in the standard direction, "R" if only used in the reverse direction, and "B" if used in both directions).

- Act/deact of persistent cyclic or periodic transmission of the addressed object

Test procedure

(station-specific parameter, mark "X" if function is only used in the standard direction, "R" if only used in the reverse direction, and "B" if used in both directions).

- Test procedure

File transfer

(station-specific parameter, mark "X" if function is used).

File transfer in monitor direction

- Transparent file
- Transmission of disturbance data of protection equipment
- Transmission of sequences of events
- Transmission of sequences of recorded analogue values

File transfer in control direction

- Transparent file

Background scan

(station-specific parameter, mark "X" if function is only used in the standard direction, "R" if only used in the reverse direction, and "B" if used in both directions).

- Background scan

Acquisition of transmission delay

(station-specific parameter, mark "X" if function is only used in the standard direction, "R" if only used in the reverse direction, and "B" if used in both directions).

Acquisition of transmission delay

Definition of time outs

| Parameter | Default value | Remarks | Selected value |
|-----------|---------------|---|-------------------|
| t_0 | 30 s | Time-out of connection establishment | adjustable |
| t_1 | 15 s | Time-out of send or test APDUs | adjustable |
| t_2 | 10 s | Time-out for acknowledges in case of no data messages $t_2 < t_1$ | adjustable |
| t_3 | 20 s | Time-out for sending test frames in case of a long idle state | adjustable |

Maximum range for timeouts t_0 to t_2 : 1 s to 255 s, accuracy 1 s.

Recommended range for timeout t_3 : 1 s to 48 h, resolution 1 s.

Long timeouts for t_3 may be needed in special cases where satellite links or dialup connections are used (for instance to establish connection and collect values only once per day or week).

Maximum number of outstanding I format APDUs k and latest acknowledge APDUs (w)

| Parameter | Default value | Remarks | Selected value |
|-----------|---------------|---|-------------------|
| k | 12 APDUs | Maximum difference receive sequence number to send state variable | adjustable |
| w | 8 APDUs | Latest acknowledge after receiving w I format APDUs | adjustable |

Maximum range of values k : 1 to 32767 ($2^{15}-1$) APDUs, accuracy 1 APDU

Maximum range of values w : 1 to 32767 APDUs, accuracy 1 APDU (Recommendation: w should not exceed two-thirds of k).

Portnumber

| Parameter | Value | Remarks |
|------------|-------|--------------|
| Portnumber | 2404 | In all cases |

Redundant connections

>16 Number N of redundancy group connections used

RFC 2200 suite

RFC 2200 is an official Internet Standard which describes the state of standardization of protocols used in the Internet as determined by the Internet Architecture Board (IAB). It offers a broad spectrum of actual standards used in the Internet. The suitable selection of documents from RFC 2200 defined in this standard for given projects has to be chosen by the user of this standard.

- Ethernet 802.3
- Serial X.21 interface
- Other selection from RFC 2200:

List of valid documents from RFC 2200

1.
2.
3.
4.
5.
6.
7. etc.